



Total Quality. Assured.

SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: I3070.03-201-47
Test End Date: 05/29/2018
Report Date: 09/25/2018
Test Record Retention End Date: 05/29/2022

SERIES TESTED: Horizontal Sliding Window
MODEL TESTED: 100 Series Gliding Window - 100GXO6050 IG

NAFS-17/-11/-08 Class LC-PG50 Size Tested 71.5 x 59.5 in. DP +50/-50

Test

Results Summary

Operating Force: 26 N (6 lbf)
Resistance to Air Infiltration: 0.07 cfm/ft^2 (ASTM E283)
Resistance to Water Penetration: Pass at DP50 (ASTM E547)
Resistance to Structural Loading: Pass at DP +50/-50 (ASTM E330)
Forced Entry Resistance: Pass (ASTM F 588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test

Rating

Operating Ease: 26 N (6 lbf)
Air Tightness: A2
Water Tightness: B3
Wind Load Resistance: C3
Blow-Out: C3
Forced Entry Resistance: F10
Screen Push-out: S1

REFERENCE: See ATI Report No. I3070.01-201-47 and I3070.02-201-47 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI

INTERTEK-ATI

Tony D. Gavin
Technician

Daniel A. Johnson
Director of Regional Operations

