



**SUMMARY TEST REPORT**

FOR: Andersen Corporation  
71 Second Street  
Strathroy, Ontario N7G 3H8  
Canada

Report Number: F9581.03-201-47  
Test End Date: 07/19/2016  
Report Date: 08/01/2016  
Test Record Retention End Date: 07/19/2020

SERIES TESTED:  
MODEL TESTED

Clad Folding Door  
Folding Outswing Door (2L2R)

**NAFS-08/-11**

SP-PG40 Size Tested 159.0 x 95.5 in. DP +40/-40 psf

**Test**

**Results Summary**

Force to Latch  
Resistance to Air Infiltration  
Resistance to Water Penetration  
Resistance to Structural Loading  
Forced Entry Resistance

31 N (7 lbf)  
0.05 cfm/ft<sup>2</sup> (ASTM E283)  
Pass at DP40 (ASTM E547)  
Pass at DP40 (ASTM E330)  
Pass (AAMA 1304)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

**Test**

**Rating**

Force to Latch  
Air Tightness  
Water Tightness  
Wind Load Resistance  
Blow-Out  
Resistance to Forced Entry

31 N (7 lbf)  
A3  
B2  
C2  
C2  
F10

**REFERENCE:**

See Intertek-ATI Report No. F9581.01-201-47 and F9581.02-201-47 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Tony D. Gavin  
Technician

Daniel A. Johnson  
Director - Regional Operations