



SUMMARY TEST REPORT

FOR: Eagle Window & Door, Inc.
 2045 Kerper Boulevard
 Dubuque, Iowa 52001

Report Number: D2358.03-201-44
 Test End Date: 02/10/2014
 Report Date: 02/18/2014
 Test Record Retention End Date: 02/10/2018

SERIES TESTED: 6050 E-Series Slide-By Window

NAFS-11	Class CW-PG30 Size Tested 1828 x 1524 mm (72.0 x 60.0 in)-HS
NAFS-08	Class CW-PG30 Size Tested 1828 x 1524 mm (72.0 x 60.0 in)-HS
Test	Results Summary
Resistance to Air Infiltration	0.05 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP30 (ASTM E547)
Resistance to Structural Loading	Pass at DP30 (ASTM E330)
Forced Entry Resistance	Pass at Grade 10 (ASTM F588)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

Test	Rating
Air Tightness	A3/Fixed
Water Tightness	B2
Wind Load Resistance	C2
Blow-Out	C2

REFERENCE: See ATI Report No. D2358.01-201-44 and D2358.02-201-44 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
 Project Manager

Daniel A. Johnson
 Director - Regional Operations

849 Western Avenue North
 St. Paul, MN 55117
 Phone: 651-636-3835
 Fax: 651-636-3843
 www.archtest.com