



SUMMARY TEST REPORT

FOR: Andersen Corporation, E-Series
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: H6183.03-201-47
Test End Date: 11/27/2017
Report Date: 12/19/2017
Test Record Retention End Date: 12/05/2021

SERIES TESTED:
MODEL TESTED

In-Swing Side-Hinged Door
E-Series SP5, In-Swing Single 3486
Class LC-PG45 Size Tested 40.5 x 102.0 in.

NAFS-08/-11

Test

Force to Latch
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Results Summary

Pass, 27 N (6 lbf) max.
0.20 cfm/ft² (ASTM E283)
Pass at DP45 (ASTM E547)
Pass at DP50 (ASTM E330)
Pass (AAMA 1304)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test

Ease of Operation
Air Tightness
Water Tightness
Wind Load Resistance
Blow-Out

Rating

27 N (6 lbf)
A3
B3
C3
C3

REFERENCE:

See ATI Report No. H6183.01-201-47 and H6183.02-201-47 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Tony D. Gavin
Technician I

Daniel A. Johnson
Director - Regional Operations