



**SUMMARY TEST REPORT**

FOR: Andersen Corporation, E-Series  
2045 Kerper Boulevard  
Dubuque, Iowa 52001

Report Number: G4239.03-201-44  
Test End Date: 01/04/2017  
Report Date: 01/18/2017  
Test Record Retention End Date: 01/04/2021

SERIES TESTED:  
MODEL TESTED

E-Series Hinged Patio Door In-swing  
6786 Hinged Patio Door - Inswing (SP4) (XX)  
Class LC-PG30 Size Tested 79.0 x 102.0 in.  
DP +30/-30

**NAFS-08/-11**

**Test**

**Results Summary**

Resistance to Air Infiltration  
Resistance to Water Penetration  
Resistance to Structural Loading  
Forced Entry Resistance

0.03 cfm/ft<sup>2</sup> (ASTM E283)  
Pass at DP40 (ASTM E547)  
Pass at DP30 (ASTM E330)  
Pass (AAMA 1304)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

**Test**

**Rating**

Air Tightness  
Water Tightness  
Wind Load Resistance  
Blow-Out  
Forced Entry Resistance

A3  
B2  
C2  
C2  
F10

**REFERENCE:**

See Intertek-ATI Report No. G4239.01-201-44 and G4239.02-201-44 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Karl A. Lips-Eakins  
Senior Technician

Daniel A. Johnson  
Director - Regional Operations