



**SUMMARY TEST REPORT**

FOR: Andersen E-Series/Eagle Window & Door  
2045 Kerper Boulevard  
Dubuque, Iowa 52001

Report Number: E6414.03-201-44  
Test End Date: 04/07/2015  
Report Date: 05/16/2015  
Test Record Retention End Date: 04/07/2019

SERIES TESTED: 3080 Series 05 E-Series Hinged Patio Door Sidelight – Inswing - SL1 with Harbor Master IG  
MODEL TESTED: Aluminum Clad Wood Fixed Door with Impact Glazing (O)

<b>NAFS-08/-11</b>	Class LC-PG45 Size Tested 927 x 2438 mm (36.5. x 96 in.)-FD Class LC-PG45 Size Tested 927 x 2438 mm (36.5. x 96 in.)-SLT
<b>Test</b> Resistance to Air Infiltration Resistance to Water Penetration Resistance to Structural Loading Forced Entry Resistance	<b>Results Summary</b> 0.04 cfm/ft <sup>2</sup> (ASTM E283) Pass at DP45 (ASTM E547/ ASTM E331) Pass at DP +50/-65 (ASTM E330) Pass (ASTM F588)

<b>ASTM E1886 / ASTM E1996</b>	
<b>Test</b> Impact Pressure Cycling	<b>Results Summary</b> No rips, tears or penetrations, Missile D, Zone 4 DP +50/-65 psf

<b>REFERENCE:</b>	See ATI Report No. E6414.01-201-44, and E6414.02-201-44 for complete test results.
-------------------	--

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**INTERTEK-ATI:**

**INTERTEK-ATI:**

Eric J. Schoenthaler  
Project Manager

Daniel A. Johnson  
Director - Regional Operations