



SUMMARY TEST REPORT

FOR: Andersen E-Series/Eagle Window & Door
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: E6410.02-201-44
Test End Date: 04/03/2015
Report Date: 09/09/2015
Test Record Retention End Date: 04/03/2019

SERIES TESTED: 3080 E-Series Hinged Patio Door Sidelight - Outswing SP1R1
with Harbor Master IG

MODEL TESTED: Aluminum Clad Fixed Door with Impact Glazing (O)
with Impact Glazing and Raised Panel

NAFS-08/-11

Class LC-PG65 927 x 2421 (37 x 95)-FD
Class LC-PG65 927 x 2421 (37 x 95)-SLT

Test

Results Summary

Operating Ease
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

(N/A)
<0.01 cfm/ft² (ASTM E283)
Pass at DP65 (ASTM E547/ ASTM E331)
Pass at DP +65/-65 (ASTM E330)
Pass (ASTM F 588)

ASTM E1886 / ASTM E1996

Test

Results Summary

Impact
Pressure Cycling

No rips, tears or penetrations, Missile D, Zone 4
DP +65/-65 psf

REFERENCE:

See Intertek-ATI Report No. E6410.01-201-44, and E6409.02-201-44 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI:

INTERTEK-ATI:

Tony D. Gavin
Technician

Daniel A. Johnson
Director of Regional Operations