



### SUMMARY TEST REPORT

FOR: Andersen E-Series/Eagle Window & Door  
2045 Kerper Boulevard  
Dubuque, Iowa 52001

Report Number: E0005.03-201-44  
Test End Date: 09/16/2014  
Report Date: 10/03/2014  
Report Revision Date: 02/25/2015  
Test Record Retention End Date: 09/16/2018

SERIES TESTED:  
MODEL TESTED

Aluminum Clad Double Hung  
3470 T7 Talon Clad Double Hung Vent  
Class LC-PG55 1016 x 2134 (40 x 84)-H\*

**NAFS-08/-11**

**Test**

**Results Summary**

Force to Latch  
Resistance to Air Infiltration  
Resistance to Water Penetration  
Resistance to Structural Loading  
Forced Entry Resistance

Pass, 98 N (22 lbf) max.  
0.15 cfm/ft<sup>2</sup> (ASTM E283)  
Pass at DP55 (ASTM E547)  
Pass at DP55 (ASTM E330)  
Pass (ASTM F 588)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

**Test**

**Rating**

Ease of Operation  
Air Tightness  
Water Tightness  
Wind Load Resistance  
Blow-Out  
Forced Entry Resistance

98 N (22 lbf)  
A2  
B4  
C3  
C3  
F10

**REFERENCE:**

See ATI Report No. E0005.01-201-44 and E0005.02-201-44 for complete test results. Reference Architectural Testing, Inc. Report No. E0004.01-201-44, dated 09/19/14 for complete *Gateway* test specimen description and test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Tony D. Gavin  
Technician

Daniel A. Johnson  
Director - Regional Operations