



SUMMARY TEST REPORT

FOR: Andersen E-Series/Eagle Window
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: E3270.02-201-44
Test End Date: 12/18/2014
Report Date: 02/13/2015
Test Record Retention End Date: 02/13/2019

SERIES TESTED: Series 02 Clad Casement with Impact Glazing
MODEL TESTED: 3056 Eyebrow with Impact Glazing

NAFS-08/-11 Class CW-PG65 Size Tested 914 x 1676 mm (36.0 x 66.0 in.)-C

Test

Operating Force
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Results Summary

Pass, 9 N (2.0 lbf) max.
<0.01 cfm/ft² (ASTM E283)
Pass at DP70 (ASTM E547)
Pass at DP65 (ASTM E330)
Pass (ASTM F 588)

ASTM E1886 - 05
ASTM E1996 - 12

Test

Impact
Pressure Cycling

Results Summary

Zone 4, Missile D
DP +55/-65 psf

REFERENCE: See Intertek-ATI Report No. E3270.01-201-44 and E3260.02-201-18 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI

INTERTEK-ATI

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations