



SUMMARY TEST REPORT

FOR: Andersen E-Series/Eagle Window & Door
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: E6415.03-201-44
Test End Date: 08/11/2015
Report Date: 08/17/2015
Test Record Retention End Date: 08/17/2019

SERIES TESTED: 6080 Series 05 E-Series Inswing French Door SP1 with Harbor Master IG
MODEL TESTED: Aluminum Clad Wood Hinged Door with Impact Glazing (Inswing)

NAFS-08/-11 Class LC-PG45 1830 x 2438 mm (72.0 x 96.0 in.)-SHD

<u>Test</u>	<u>Results Summary</u>
Operating Ease	(N/A)
Resistance to Air Infiltration	0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP45 (ASTM E547/ ASTM E331)
Resistance to Structural Loading	Pass at DP +50/-65 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)

ASTM E1886 / ASTM E1996

<u>Test</u>	<u>Results Summary</u>
Impact	No rips, tears or penetrations, Missile D, Zone 4
Pressure Cycling	DP +50/-65 psf

REFERENCE:	See Intertek-ATI Report No. E6415.01-201-44, and E6415.02-201-44 for complete test results.
-------------------	---

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI:

INTERTEK-ATI:

Tony D. Gavin
Technician

Daniel A. Johnson
Director of Regional Operations