



**SUMMARY TEST REPORT**

FOR: Andersen E-Series/Eagle Window & Door  
2045 Kerper Boulevard  
Dubuque, Iowa 52001

Report Number: F2052.02-201-44  
Test End Date: 12/07/2015  
Report Date: 01/20/2016  
Test Record Retention End Date: 12/07/2019

SERIES TESTED: Aluminum Clad Wood Casement with Impact Glazing  
MODEL TESTED: 3060 Series 11 Casement with HMIG

**NAFS-08/-11** Class CW-PG65 Size Tested 914 x 1829 mm (36.0 x 72.0 in.)-C

**Test**

Operating Force  
Resistance to Air Infiltration  
Resistance to Water Penetration  
Resistance to Structural Loading  
Forced Entry Resistance

**Results Summary**

Pass, 18 N (4 lbf) max.  
<0.01 cfm/ft<sup>2</sup> (ASTM E283)  
Pass at DP65 (ASTM E547)  
Pass at DP+65/-75 (ASTM E330)  
Pass (ASTM F 588)

**ASTM E1886 / ASTM E1996**

**Test**

Impact  
Pressure Cycling

**Results Summary**

No rips, tears or penetrations, Missile D, Zone 4  
DP +65/-75 psf

**REFERENCE:**

See ATI Report No. F2052.01-201-44 and F2039.02-201-18 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Tony D. Gavin  
Technician

Daniel A. Johnson  
Director - Regional Operations