



SUMMARY TEST REPORT Structural Testing

FOR: Andersen E-Series/Eagle Window & Door
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: F2062.03-201-44
Test End Date: 10/12/2015
Report Date: 11/24/2015
Test Record Retention End Date: 10/12/2019

SERIES TESTED:
MODEL TESTED

Aluminum Clad Wood Push-out Casement
3060 Series 11 Clad Push-out Casement
Class LC-PG50 914 x 1829 (36 x 72)-C

NAFS-08/-11

Test

Operating Force
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Results Summary

Pass, 13 N (3 lbf) max.
<0.01 cfm/ft² (ASTM E283)
Pass at DP50 (ASTM E547)
Pass at DP50 (ASTM E330)
Pass (ASTM F 588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test

Ease of Operation
Air Tightness
Water Tightness
Wind Load Resistance
Blow-Out

Rating

13 N (3 lbf)
A3
B3
C3
C3

REFERENCE:

See Intertek-ATI Report No. F2062.01-201-44 and F2062.02-201-44 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI

INTERTEK-ATI

Tony D. Gavin
Technician

Daniel A. Johnson
Director - Regional Operations