



SUMMARY TEST REPORT

FOR: Andersen Corporation, E-Series
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: G0169.03-201-44
Test End Date: 07/11/2016
Report Date: 09/22/2016
Test Record Retention End Date: 09/22/2020

SERIES TESTED: E-Series French Gliding Patio Door Sidelite with Harbor Master Mono
MODEL TESTED: 4080

NAFS-08/-11	Class LC-PG60 1270 x 2438 (50 x 96)-FD and Class LC-PG60 1270 x 2438 (50 x 96)-SLT DP +60/-65 psf
<u>Test</u>	<u>Results Summary</u>
Resistance to Air Infiltration Resistance to Water Penetration Resistance to Structural Loading Forced Entry Resistance	0.02 cfm/ft ² (ASTM E283) Pass at DP60 (ASTM E547) Pass at DP +60/-65 (ASTM E330) Pass (ASTM F842)
ASTM E1886, E1996	
<u>Test</u>	<u>Results Summary</u>
Impact Pressure Cycling	Wind Zone 4, Missile level D DP +60/-65 psf
Dade County Testing	
<u>Test</u>	<u>Results Summary</u>
TAS 202 TAS 201 TAS 203	Pass at DP +60/-65 psf Pass (Large Missile) Pass at +60/-65 psf
REFERENCE:	See Intertek-ATI Report No. G0169.01-201-44, G0169.02-201-44 and G0149.01-201-18 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC.

ARCHITECTURAL TESTING, INC.

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations