



SUMMARY TEST REPORT

FOR: Andersen Corporation, E-Series
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: G0171.03-201-44
Test End Date: 07/11/2016
Report Date: 09/22/2016
Test Record Retention End Date: 09/22/2020

SERIES TESTED: E-Series Hinged Patio Door Outswing Transom with Harbor Master Mono
MODEL TESTED: 6030

NAFS-08/-11	Class LC-PG65 1829 x 914 (72 x 36)-TR DP +65/-65 psf
Test	Results Summary
Resistance to Air Infiltration	<0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP65 (ASTM E547)
Resistance to Structural Loading	Pass at DP +65/-65 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F588)

ASTM E1886, E1996	
Test	Results Summary
Impact	Wind Zone 4, Missile level D
Pressure Cycling	DP +65/-65 psf

Dade County Testing	
Test	Results Summary
TAS 202	Pass at DP +65/-65 psf
TAS 201	Pass (Large Missile)
TAS 203	Pass at +65/-65 psf

REFERENCE:	See Intertek-ATI Report No. G0171.01-201-44, G0171.02-201-44 and G0152.01-201-18 for complete test results.
-------------------	---

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC.

ARCHITECTURAL TESTING, INC.

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations