

SUMMARY TEST REPORT

FOR: Andersen Corporation
100 4th Avenue North
Bayport, Minnesota 55003

Report Number: K7456.02-201-44
Test End Date: 06/03/2020
Report Date: 07/29/2020
Test Record Retention End Date: 06/03/2024

SERIES/MODEL TESTED

Contemporary Clad Wood Stormwatch Folding Outswing Door 4 Panel, 4R with High Performance Sill

NAFS-17, -11, -08
CSA A440S1-17, -09

Class LC-PG50 Size Tested 146.6 x 119.5 in.
DP +50/-50 psf

Test

Operating force
Resistance to Air Infiltration
Resistance to Water Infiltration
Resistance to Structural Loading
Forced Entry Resistance

Results Summary

36 N (8 lbf) Force to Latch
0.04 cfm/ft² (ASTM E283)
Pass at DP +50 (ASTM E547)
Pass at DP +50/-50 (ASTM E330)
Pass (AAMA 1304)

Test

Dade Co. TAS 201, 202, 203
ASTM E 1886, E 1996
Impact
Pressure Cycling

Results Summary

Zone 4, Missile D
+50/-50 psf

REFERENCE:

See Intertek B&C Report No. K7456.01-201-44, K7450.01-201-18, and K7450.02-201-44 for complete test results.

A copy of this report will be retained by Intertek B&C for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK B&C

INTERTEK B&C

Karl Lips
Senior Technician

Daniel A. Johnson
Director - Regional Operations

