



SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: E3093.03-201-47
Test End Date: 11/19/2014
Report Date: 12/09/2014
Test Record Retention End Date: 12/09/2018

SERIES TESTED: 100 Series Casement Window
MODEL TESTED: 100CS3060 IG

NAFS-08/-11	Class LC-PG40 Size Tested 35.5 x 71.5 in. DP+40/-45
<u>Test</u>	<u>Results Summary</u>
Ease of Operation	Pass, 22 N (5.0 lbf) max.
Resistance to Air Infiltration	0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP40 (ASTM E547)
Resistance to Structural Loading	Pass at DP +40/-45 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 588)

CAN/CSA A440-00 , Evaluation to the prescriptive requirements were not performed	
<u>Test</u>	<u>Rating</u>
Ease of Operation	22 N (5.0 lbf)
Air Tightness	A3
Water Tightness	B2
Wind Load Resistance	C2
Blow-Out	C2
Insect Screen Strength	S1
Resistance to Forced Entry	F10

REFERENCE:	See ATI Report No. E3093.01-201-47, and E3093.02-201-47 for complete test results.
-------------------	--

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director - Regional Operations