



**SUMMARY TEST REPORT**

FOR: Andersen Corporation  
100 Fourth Avenue North  
Bayport, Minnesota 55003

Report Number: D0666.03-201-47  
Test End Date: 12/23/2013  
Report Date: 07/24/2014  
Test Record Retention End Date: 12/23/2017

SERIES TESTED: A-Series Frenchwood Gliding Patio Door  
MODEL TESTED: FWGD80100AS IR DPUP

**NAFS-08/-11** Class LC-PG55 Size Tested 95.2" x 119.5" DP +55/-55

<u>Test</u>	<u>Results Summary</u>
Operating Ease	Pass, 27 N (6.0 lbf) max.
Resistance to Air Infiltration	0.04 cfm/ft <sup>2</sup> (ASTM E283)
Resistance to Water Penetration	Pass at DP55 (ASTM E547 and ASTM E331)
Resistance to Structural Loading	Pass at DP +55/-55 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F842)

**CAN/CGSB-82.1-M89**, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Air Tightness	A3
Water Tightness	B4
Wind Load Resistance	C2
Blow-Out	C3
Operating Ease	E3
Forced Entry Resistance	F1

<u>Test</u>	<u>Results Summary</u>
Impact	No rips, tears or penetrations
Pressure Cycling	Pass at DP +55/-55

<b>REFERENCE:</b>	See ATI Report No. D0666.01-201-44 and D0624.02-201-18, for complete test results.
-------------------	--

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Eric J. Schoenthaler  
Project Manager

Daniel A. Johnson  
Director - Regional Operations