



SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, Minnesota 55003

Report Number: D0674.03-201-44
Test End Date: 09/13/2013
Report Date: 08/07/2014
Test Record Retention End Date: 09/13/2017

SERIES TESTED: A-Series Frenchwood Hinged Patio Door - Inswing with Stormwatch Protection
MODEL TESTED: FWHD33100S IR DPUP

NAFS-08/-11 Class LC-PG65 Size Tested 38.1" x 119.5" DP +65/-70

<u>Test</u>	<u>Results Summary</u>
Resistance to Air Infiltration	0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP65 (ASTM E547 and ASTM E331)
Resistance to Structural Loading	Pass at DP +65/-70 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F588)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Air Tightness	A3
Water Tightness	B4
Wind Load Resistance	C3
Blow-Out	C3
Forced Entry Resistance	Pass

<u>Test</u>	<u>Results Summary</u>
Impact	No rips, tears or penetrations
Pressure Cycling	Pass at DP +65/-70

REFERENCE:	See ATI Report No. D0674.01-201-44, D0674.02-201-44 and D0628.02-201-18, for complete test results.
-------------------	---

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations