Intertek | Architectural Testing

SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: F3522.03-201-47
Test End Date: 12/17/2015
Report Date: 02/01/2016
Test Record Retention End Date: 12/17/2019

SERIES TESTED: A-Series Frenchwood Hinged Patio Door – Inswing / FWHID6480AP IG
MODEL TESTED Hinged Inswing Wood Door (XX)

NAFS-08/-11 Class LC-PG45 Size Tested 75.3" x 95.5" DP +45/-55

Test	**Results Summary**
Force to Latch	22 N (5 lbf)
Resistance to Air Infiltration	0.02 cfm/ft^2 (ASTM E283)
Resistance to Water Penetration	Pass at DP45 (ASTM E547)
Resistance to Structural Loading	Pass at DP+45/-55 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test	**Rating**
Ease of Operation	22 N (5 lbf)
Air Tightness	A3
Water Tightness	B3
Wind Load Resistance	C3
Blow-Out	C3
Resistance to Forced Entry	Pass

REFERENCE:	See Intertek-ATI Report No. F3522.01-201-47 and F3522.02-201-47 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

Digitally Signed by: Anthony Gavin

Tony D. Gavin
Technician

ARCHITECTURAL TESTING, INC

Digitally Signed by: Daniel A. Johnson

Daniel A. Johnson
Director - Regional Operations