Architectural Testing

SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, Minnesota 55003

Report Number: D2577.03-201-44
Test End Date: 10/23/2013
Report Date: 03/07/2014
Test Record Retention End Date: 01/31/2018

SERIES TESTED: A-Series Frenchwood Hinged Patio Door-Inswing with Stormwatch Protection/FWHID3380A IG IR

MODEL TESTED Hinged Inswing Wood Door (X)

NAFS-08/-11

Class LC-PG45 Size Tested 38.1" x 95.5"
DP+45/-70

Test	**Results Summary**
Operating Ease	Pass, 31 N (7 lbf) max.
Resistance to Air Infiltration	0.03 cfm/ft^2 (ASTM E283)
Resistance to Water Penetration	Pass at DP45 (ASTM E547)
Resistance to Structural Loading	Pass at DP45 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test	**Rating**
Operating Ease	31 N (7 lbf) max.
Air Tightness	A3
Water Tightness	B3
Wind Load Resistance	C3
Blow-Out	C3

Test	**Results Summary**
Impact	No rips, tears or penetrations
Pressure Cycling	DP+45/-70

REFERENCE:	See ATI Report No. D2577.01-201-44, D2577.02-201-44 and D2577.04-201-44 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

Digitally Signed by: Anthony Gavin

Tony D. Gavin
Technician

ARCHITECTURAL TESTING, INC

Digitally Signed by: Daniel A. Johnson

Daniel A. Johnson
Director - Regional Operations

849 Western Avenue North
St. Paul, MN 55117
Phone: 651-636-3835
Fax: 717-764-4129
www.archtest.com