



SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: C9409.03-201-47
Test End Date: 05/28/2013
Report Date: 07/10/2013
Test Record Retention End Date: 07/10/2017

SERIES TESTED: 100 Series Gliding Door
MODEL TESTED: 100GD2P8080 IG

NAFS-08/-11 Class LC-PG30 Size Tested 95.5 x 95.5 in. DP+30/-30
NAFS-05 N/A

<u>Test</u>	<u>Results Summary</u>
Operating Ease	36 N (8 lbf)
Resistance to Air Infiltration	0.20 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP30 (ASTM E547)
Resistance to Structural Loading	Pass at DP30 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 842)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Operating Ease	E3
Air Tightness	A1
Water Tightness	B2
Wind Load Resistance	C1
Blow-Out	C2

<u>Test</u>	<u>Results Summary</u>
Impact	(N/A)
Pressure Cycling	(N/A)

REFERENCE: See ATI Report No. C9409.01-201-47 and C9409.02-201-47 for complete test results

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director of Regional Operations

849 Western Avenue North
St. Paul, MN 55117
Phone: 651-636-3835
Fax: 717-764-4129
www.archtest.com