



SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: D8511.03-201-47
Test End Date: 07/14/2014
Report Date: 09/02/2014
Test Record Retention End Date: 07/14/2018

SERIES TESTED: 200 Series Hinged Patio Door - Inswing/ISPD6080AP IG
MODEL TESTED: Fiberglass Hinged Glass Door (XX)
NAFS-08/-11 Class LC-PG30 Size Tested 71.3 x 95.5 in. DP+30/-35

Test

Results Summary

Force to Latch	40 N (9 lbf) max.
Resistance to Air Infiltration	0.06 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP30 (ASTM E547)
Resistance to Structural Loading	Pass at DP30 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

Test

Rating

Force to Latch	40 N (9 lbf)
Air Tightness	A3
Water Tightness	B2
Wind Load Resistance	C3
Blow-Out	C2
Resistance to Forced Entry	AAMA 1304

REFERENCE:

See ATI Report No. D8511.01-201-47 and D8511.02-201-47 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director - Regional Operations