



**SUMMARY TEST REPORT**

FOR: Andersen Corporation  
100 Fourth Avenue North  
Bayport, MN 55003

Report Number: E1935.03-201-47  
Test End Date: 01/28/2015  
Report Date: 02/13/2015  
Test Record Retention End Date: 02/13/2019

SERIES TESTED: 200 Series Narroline Gliding Patio Door/NLGD16080SAAS IG  
MODEL TESTED: Sliding Door

<b>NAFS-08/-11</b>	Class LC-PG25 Size Tested 189.0 x 95.5 in. DP +25/-25
<b><u>Test</u></b>	<b><u>Results Summary</u></b>
Operating Force	Pass, 22 N (5.0 lbf) max.
Resistance to Air Infiltration	0.08 cfm/ft <sup>2</sup> (ASTM E283)
Resistance to Water Penetration	Pass at DP25 (ASTM E547)
Resistance to Structural Loading	Pass at DP25 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 842)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

<b><u>Test</u></b>	<b><u>Rating</u></b>
Ease of Operation	36 N (8 lbf)
Air Tightness	A3
Water Tightness	B1
Wind Load Resistance	FAIL
Blow-Out	N/A
Resistance to Forced Entry	F10

**REFERENCE:** See ATI Report No. E1935.01-201-47 and E1935.02-201-47 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**INTERTEK-ATI**

Karl A. Lips-Eakins  
Senior Technician

**INTERTEK-ATI**

Daniel A. Johnson  
Director - Regional Operations