



SUMMARY TEST REPORT

FOR: Eagle Window & Door, Inc.
 2045 Kerper Boulevard
 Dubuque, Iowa 52001

Report Number: D0707.03-201-44
 Test End Date: 12/04/2013
 Report Date: 12/14/2013
 Test Record Retention End Date: 12/04/2017

SERIES TESTED: 3080 E-Series Hinged Patio Door - Outswing with Harbor Master IG muller to a
 3080 E-Series Hinged Patio Door Sidelight - Outswing with Harbor Master IG

NAFS-11

Class LC-PG65 927 x 2421 (36 x 95)-SHD

Class LC-PG65 927 x 2421 (36 x 95)-FD

Class LC-PG65 927 x 2421 (36 x 95)-SLT

NAFS-08

Class LC-PG65 927 x 2421 (36 x 95)-SHD

Class LC-PG65 927 x 2421 (36 x 95)-FD

Class LC-PG65 927 x 2421 (36 x 95)-SLT

AAMA 450

Class LC-PG65 - 95.31" Span x 38.50" Tributary Width - MA Rein Mull - Vertical

Test

Resistance to Air Infiltration
 Resistance to Water Penetration
 Resistance to Structural Loading
 Forced Entry Resistance

Results Summary

<0.01 cfm/ft² (ASTM E283)
 Pass at DP65 (ASTM E547)
 Pass at DP65 (ASTM E330)
 Pass (AAMA 1304)
 Pass at Grade 10 (ASTM F588)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

Test

Air Tightness
 Water Tightness
 Wind Load Resistance
 Blow-Out

Rating

A3
 B4
 C3
 C3

REFERENCE:

See ATI Report No. D0707.01-201-44 and D0707.02-201-44
 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
 Project Manager

Daniel A. Johnson
 Director - Regional Operations

849 Western Avenue North
 St. Paul, MN 55117
 Phone: 651-636-3835
 Fax: 651-636-3843
 www.archtest.com